

This Research Report is issued under the fixed designation RR: D02-1218. You agree not to reproduce or circulate or quote, in whole or part, this document outside of ASTM International Committee/Society activities, or submit it to any other organization or standards body (whether national, international or other) except with the approval of the Chairman of the Committee having jurisdiction and the written authorization of the President of the Society. If you do not agree to these conditions, please immediately destroy all copies of this document. *Copyright ASTM International, 100 Barr Harbor Drive, West Conshohocken, PA 19428. All rights reserved.*

**31 December 1987**

## **Committee D02 on Petroleum Products and Lubricants**

### **Research Report D02-1218**

#### **Instrumentation Task Force Report to the ASTM Technical Guidance Committee**

ASTM International  
100 Barr Harbor Drive  
West Conshohocken, PA 19428-2959

INSTRUMENTATION TASK FORCE REPORT  
TO THE  
ASTM TECHNICAL GUIDANCE COMMITTEE  
(ASTM Committee D-2, Subcommittee B)

APRIL 22, 1987

## CONTENTS

I. Introduction	p. 1
II. Scope & Objectives	p. 1
III. Recommendations	
A. Performance Specifications	p. 1
1. Accuracy	p. 1
2. Frequency Response	p. 2
B. Calibration Guidelines	p. 2
C. Equivalency Guidelines	p. 3
D. Other Recommendations	p. 3
IV. Appendix	
A. Membership	p. 5
B. Definitions	p. 6
C. Instrument Devices' Response Characteristics	p. 8
D. Data Index	p. 10
E. References	p. 61

## I. INTRODUCTION

There is a growing use of electronic process measuring instrumentation for supporting the operations of ASTM engine-dynamometer type lubricant tests, particularly those using automated data acquisition systems. This Task Force was formed to develop instrumentation guidelines that will provide uniformity in process measurements throughout this testing industry.

This Task Force was formed in January of 1986. (See Appendix A for membership list.) Meetings were held to discuss instrumentation used by this industry and to develop guidelines for their selection and use. This report is the summary of the findings of this group for implementation in new and existing test procedures.

## II. SCOPE & OBJECTIVES

The objective of the Task Force was set to provide performance definitions for instrumentation in STP's 315H and 509A. This involves recommending replacement terminology based on such items as accuracy and frequency response rather than based on brand names or generic types. In order to more clearly define the objective, the following three goals were established.

- A. Issue guidelines for instrumentation system specifications with performance definitions for accuracy and frequency response.
- B. Issue calibration guidelines and procedures including record keeping.
- C. Issue guidelines for showing equivalency.

## III. RECOMMENDATIONS

### A. PERFORMANCE SPECIFICATIONS

The Task Force agreed that independent of the hardware used, any instrumentation used for enhanced or automated systems must translate data into values of comparable accuracy and frequency response to those obtained with the accepted manual systems. The Task Force's efforts are aimed at defining instrumentation limits for specified operating conditions. The desire would be for the Operations and Hardware (O&H) subpanels to incorporate comparable limits on "record only" values.

#### 1. ACCURACY

The desired accuracy of the measurement is important, but only as important as that parameter is to the test procedure. Based on current instrumentation technology and test procedures, the Task Force recommends the accuracy to be 20% of the test specification deviation, e.g., for  $100^{\circ}\text{F} \pm 5^{\circ}\text{F}$ , the accuracy is 20% of  $\pm 5^{\circ}\text{F}$  which is  $\pm 1^{\circ}\text{F}$ . This limits the worst case actual deviation from test specification to 20% of the allowable deviation above the high or below the low limits. However, there are technical limitations for these values, e.g.:

Temperature:	$\pm 0.5^{\circ}\text{F}$
Pressure, low:	$\pm 0.05'' \text{H}_2\text{O}$
high:	$\pm 0.1'' \text{Hg}$
Speed:	$\pm 1$ count per gating period

### III. RECOMMENDATIONS

#### A. PERFORMANCE SPECIFICATIONS (Cont'd)

##### 2. FREQUENCY RESPONSE

The desired frequency response of the measured parameters must be established. There are examples of extreme frequency variations in the parameter value, however, only the average value is of interest. It is recommended that this known high frequency variation be attenuated to 20% of allowable test procedure deviation or its normal minimum as outlined in Performance Specification Accuracy section.

Example: Caterpillar Crankcase Vacuum  $1 \pm 0.5$ " H<sub>2</sub>O (App. D7)

The crankcase vacuum variation, following the movement of the piston at 1800 RPM, has a frequency of 30 Hz. These pressure variations have been measured to be 30" H<sub>2</sub>O peak to peak (15" H<sub>2</sub>O baseline to peak). Based on the above guideline, it is desired<sup>2</sup> to reduce that variation to 0.1" H<sub>2</sub>O (20% of 0.5" H<sub>2</sub>O). This requires -43.5 dB ( $20 \log 0.1/15.0$ ) of filtering, of a first order filter with a cutoff frequency of 0.2 Hz

( $f_c = f_{\text{noise}} 10^{\text{dB}/20} = 30 \cdot 10^{-43.5/20}$ ). The frequency response for a green fluid manometer is 0.64 Hz, hence, the reason for a varying manometer column. For this parameter, it would be desirable to have more filtering than is inherent in a water manometer.

In order to design a reliable instrument measuring system, it is necessary to understand the frequency response capabilities and limitations of the instrument devices that are commonly used. Electronic instruments with high frequency responses shall be allowed to be filtered (mechanically, electrically or digitally) to give equivalent readings to the historically more commonly used manual types of instrument systems with lower frequency responses. See Appendix B for definitions and Appendix C for a list of instrument devices' response characteristics.

#### B. CALIBRATION GUIDELINES

General guidelines were developed that will apply to all instrumentation systems. The Task Force considers the transmitter (manometer, transducer, etc.), the element (thermocouple, flowmeter, etc.) and the location of the element as parts of the system.

1. The Laboratory calibration standards will be traceable to a defined national standard, e.g., National Bureau of Standards, and be verified at least annually.
2. The time limit for verifying that laboratory equipment meets the laboratory standard is to be as defined in the test procedure. If no time interval is specified in the procedure, then it will be defined by the Operations and Hardware Groups.
3. Test measurement systems shall be calibrated at a frequency as prescribed by the individual test procedures. It is the Task Force's recommendation that all systems be calibrated a minimum of once every six months, or at any time the readout data indicates the need.

### III. RECOMMENDATIONS

#### B. CALIBRATION GUIDELINES (Cont'd)

4. When calibrating a system, it is desirable to check the entire system as a complete unit, but if necessary, a summation of the individual system components calibration would be considered acceptable.
5. All measurement systems shall be checked at a minimum of three points along their operating range where feasible.
6. All calibrations shall be fully documented with complete indication of calibration prior to any adjustments, and what adjustments were made to achieve final calibration. This calibration documentation shall be retained by the laboratory as a permanent record for a minimum of 2 years.
7. Special instrumentation (such as an exhaust gas analyzer) which require zeroing and spanning as a part of the instrument set-up procedures do not have to comply with the above guidelines, but rather the manufacturer's recommendations are to be the guidelines or as prescribed by the test procedure.

#### C. EQUIVALENCY GUIDELINES

The Task Force realizes that equivalency of measurement systems is extremely important, especially when it comes to maintaining test severity while changing from gages to pressure transducers or from thermocouples to resistance thermal devices (RTDs). The following guidelines are to be used for establishing equivalency of complete systems or any part thereof.

1. The Test Monitoring Center (TMC) is the focal point for presentation of proposed instrumentation technology.
2. The TMC shall approve any proposed instrumentation system after being satisfied that such a system meets all calibration and performance guidelines, which may include concurrent operation with an accepted system.
3. The TMC should decide whether the proposed instrumentation needs more documentation via the following sources:
  - a. Operation & Hardware Subpanel
  - b. Test Developer
  - c. Test Surveillance Panel
4. All documentation obtained during such an equivalency study shall be retained as part of the laboratory's permanent records.

#### D. OTHER RECOMMENDATIONS

1. The Task Force recommends that each O & H subpanel establish an ad hoc committee to review instrumentation practices for new and existing procedures.

### III. RECOMMENDATIONS

#### D. OTHER RECOMMENDATIONS (Cont'd)

Pertinent examples are:

a. Pressure measurement specifications should include:

Port size  
Port location

Drawings should be provided with exact dimensions.

b. Temperature measurement specifications should include:

Element size  
Element location  
Element immersion depth

Drawings should be provided with exact dimensions.

c. Flow measurements should be specified in mass units for critical flow applications.

2. In general, it is desirable that allowable parameter deviations be established such that they not exceed the accuracies of measuring devices. However, for a critical measurement which requires an accuracy better than the measuring device, procedures shall be provided detailing the specific techniques to be used to achieve the desired accuracies.
3. Because of the time responses required for certain measurements as discussed in this report, the Instrumentation Task Force has redefined the term DATA POINT from the original definition by the Data Acquisition Task Force.

DATA POINT: The value of a parameter after appropriate digital/analog filtering with due consideration for the time constants of the system. (Many greater than one second).

APPENDIX A

INSTRUMENTATION TASK FORCE MEMBERSHIP

<u>NAME</u>	<u>COMPANY</u>
Trevor A. Brettell, Chairman	Parmins, Exxon Chemical Technology Centre
Herbert E. Harpster, Secretary	The Lubrizol Corporation
Robert J. Belling	General Motors Research Laboratories
Samuel H. Crites	Ethyl Petroleum Additives Division
Robert P. Gauss, Jr.	Southwest Research Institute
John Glaser	EG&G Automotive Research, Inc.
Greg H. Guinther	ASTM Test Monitoring Center
Richard F. Irwin	Chevron Research Company
Herbert H. Kube	Shell Canada, Ltd.
William M. Nahumck	The Lubrizol Corporation
Robert A. Ratliff	EG&G Automotive Research, Inc.
John J. Skuzinski, Jr.	AutoResearch Laboratories, Inc.

## APPENDIX B

### DEFINITIONS

In order to establish common terminology for discussion of the various aspects in process measurement instrumentation, the following definitions were established.

**PRECISION:** The degree of mutual agreement between individual measurements from the process (App. E-1).

**ACCURACY:** The degree of agreement of an individual measurement with an accepted reference level of the property in the material measured (App. E-1).

**ORDER:** The number of energy storage devices in the system. (Most process systems can be reduced to first order, i.e. one dominant energy storage device.)

**FILTER:** A means of attenuating signals in a given frequency range. They can be mechanical (volume tank, spring, mass) and/or electrical (capacitance, inductance) and/or digital (mathematical formulas). Typically, a low-pass filter attenuates the unwanted high frequency noise.

**DECIBEL (dB):** A unit for measuring the ratio of the magnitude of two quantities (normally output voltage to input voltage). Calculated as follows:

$$\text{dB} = 20 \cdot \log(\text{Output}/\text{Input})$$

**TIME CONSTANT ( $\tau$ ):** A value which represents a measure of the time response of a system. For a first order system responding to a step change in input, it is the time required for the output to reach 63.2% of its final value.

**CUTOFF FREQUENCY ( $f_c$ ):** The frequency point that divides the frequencies that pass through the system almost unattenuated and the frequencies that pass through the system but are greatly attenuated. For a first order system, this value is calculated as follows:

$$f_c = 1/(2\tau)$$

Where  $\tau$  is the time constant

DEFINITIONS

- SAMPLE FREQUENCY ( $f_s$ ):** The frequency at which a value is obtained for processing. This is normally considered for computer data acquisition, but is also true of a manual reading, i.e. once per hour.
- INPUT FREQUENCY ( $f_{in}$ ):** The frequency of the input signal. This is most certainly changing and includes real but unwanted noise. (Normally the noise is a higher frequency than the frequency of the expected signal.)
- ALIASING:** Sampling-induced low frequency noise. This occurs when the sampling frequency is very close to the input frequency thus creating a beat frequency.
- DATA POINT:** The value of a parameter after appropriate digital/analog filtering with due consideration for the time constants of the system (many greater than one second).

The following symbols are used in the remaining definitions:

- $i, j$  : Indices for data parameter or point values  
 OUT ( ) : Filtered data point  
 IN ( ) : Unfiltered parameter value  
 EXP ( ) : Value of e raised to a power  
 SUM ( ) : A summation of values

- FIRST ORDER DIGITAL FILTER:** The digital equivalent to a first order analog filter (electrical or mechanical). The formula is as follows:

$$OUT(i) = EXP(-1/(f_s \tau)) * OUT(i-1) + [1 - EXP(-1/(f_s \tau))] * IN(i)$$

- ROLLING AVERAGE DIGITAL FILTER:** A digital filter that continually calculates the average of the most recent values over the rolling time period,  $T_{RA}$ . The formula is as follows:

$$OUT(i) = SUM [IN(j), j= i - f_s T_{RA} + 1 \text{ to } i] / f_s T_{RA}$$

- BLOCK AVERAGE DIGITAL FILTER:** A digital filter that calculates the average of the values over the block time period,  $T_{BA}$  and maintains that result until the next block of values has been collected and calculated. The formula is as follows:

$$OUT(i) \text{ thru } OUT(i + T_{BA} f_s - 1) = SUM [IN(j), j= i - f_s T_{BA} + 1 \text{ to } i] / f_s T_{BA}$$

APPENDIX C

INSTRUMENT DEVICES' RESPONSE CHARACTERISTICS

Manometers (App. D2):

Green Fluid, SG = 1	$f_c = 0.64 \text{ Hz}$	$\tau = 0.25 \text{ s}$
Mercury	$f_c = 0.83 \text{ Hz}$	$\tau = 0.19 \text{ s}$
100% Glycol	$f_c = 0.22 \text{ Hz}$	$\tau = 0.72 \text{ s}$

Bourdon Tube (App. D6):

$f_c = 0.03 \text{ Hz}$	$\tau = 5.31 \text{ s}$
-------------------------	-------------------------

Strain Gage (App. D6):

$f_c = 1500 \text{ Hz}$	$\tau = 0.11 \text{ ms}$
-------------------------	--------------------------

Thermocouples (App E-2):

For grounded devices in air

1/8"	$f_c = 0.012 \text{ Hz}$	$\tau = 13 \text{ s}$
3/16"	$f_c = 0.006 \text{ Hz}$	$\tau = 24 \text{ s}$
1/4"	$f_c = 0.004 \text{ Hz}$	$\tau = 44 \text{ s}$

Resistance Thermal Device (RTD) (App E-3):

For 1000-ohm device in water

1/8"	$f_c = 0.080 \text{ Hz}$	$\tau = 2 \text{ s}$
3/16"	$f_c = 0.053 \text{ Hz}$	$\tau = 3 \text{ s}$
1/4"	$f_c = 0.040 \text{ Hz}$	$\tau = 4 \text{ s}$

Thermocouples (App. D3):

For Type J grounded in oil (32°F to 300°F)

1/8"	$f_c = 0.028 \text{ Hz}$	$\tau = 5.67 \text{ s}$
3/16"	$f_c = 0.017 \text{ Hz}$	$\tau = 9.45 \text{ s}$
1/4"	$f_c = 0.009 \text{ Hz}$	$\tau = 17.27 \text{ s}$

Resistance Thermal Device (RTD) (App. D3)

For 1000-ohm closed ungrounded device in oil (32°F to 300°F)

3/16"	$f_c = 0.011 \text{ Hz}$	$\tau = 14.28 \text{ s}$
-------	--------------------------	--------------------------

APPENDIX C (Cont'd)

INSTRUMENT DEVICES' RESPONSE CHARACTERISTICS

Liquid Rotometer, IIID Test (App D6)  $f_c = 0.035 \text{ Hz}$   $\tau = 4.54 \text{ s}$

Liquid Mass Flow by Weight  $f_c = 0.0016 \text{ Hz}$   $T_{BA} = 100 \text{ s}$

Gas Volume Flow by Natural Gas Meter  $f_c = 0.0005 \text{ Hz}$   $T_{BA} = 300 \text{ s}$

Speed by Gated Counter  $f_c = 0.16 \text{ Hz}$   $T_{BA} = 1 \text{ s}$

APPENDIX D


DATA INDEX

FOR REFERENCE DATA GENERATED

BY INSTRUMENTATION TASK FORCE MEMBERS

- D1. Static and Dynamic Parameter Limits for Sequence Tests, by Data Acquisition Task Force, 1985. p. 11
- D2. Manometer Responses for Different Fluids, by Bob Ratliff, EG&G, 1986. p. 17
- D3. RTD and T/C Response Times, by Bob Ratliff, EG&G, 1986. p. 21
- D4. Caterpillar Fuel Pressure Responses, by Trevor Brettell, Exxon, 1986. p. 23
- D5. Buick IIIIE Responses for Controlled Parameters, from an Automated Stand, by Bob Belling, GMR, 1986. p. 26
- D6. Buick IIIIE Responses for Controlled Parameters from a Manual Stand, by Bob Belling, GMR, 1986. p. 43
- D7. Pressure Responses (Ford V-D Exhaust, Caterpillar Boost and Crankcase), by Bob Gauss, SWRI, 1986 & 1987. p. 49
- D8. Relationship Between Types of Filters, by Herb Harpster, Lubrizol, 1986. p. 53

DETROIT DIESEL 8V-71  
VALVE GUTTERING TEST



APPENDIX D1

"Suggested Static and Dynamic Limits for Rejecting Bad Quality Data"

SEQUENCE I/D TEST

PARAMETER		STATIC LIMITS		RATE OF CHANGE LIMITS	
		MINIMUM	MAXIMUM		
Average speed	RPM	0	4000	Up: 88 RPM/sec Down: 165 RPM/sec	
Brake Load	Lb-ft	Hot	0	200	
		Cold	0	100	
B.H.P.		0	150		
Oil at filter block	Deg F	Hot	32	400	Up: 20 Deg F/min Down: 60 Deg F/min
		Cold		150	
Oil pan temperature	Deg F	Hot	32	400	Up: 20 Deg F/min Down: 60 Deg F/min
		Cold		150	
Oil pump outlet press	psi	Hot	0	120	30 psi/sec
Oil, engine pressure	psi	Hot	0	120	30 psi/sec
Coolant, jacket out	Deg F	Hot	32	300	Up: 12 Deg F/min Down: 28 Deg F/min
		Cold	32	150	
Coolant, jacket in	Deg F	Hot	32	300	Up: 12 Deg F/min Down: 28 Deg F/min
		Cold	32	150	
Coolant, jacket flow	GPM	0	100	5 GPM/min	
Coolant, Breather out	Deg F	Hot	32	300	Up: 12 Deg F/min Down: 28 Deg F/min
		Cold	32	150	
Coolant, left cover out	Deg F	Hot	32	300	Up: 12 Deg F/min Down: 28 Deg F/min
		Cold	32	150	
Coolant, rt cover out	Deg F	Hot	32	300	Up: 12 Deg F/min Down: 28 Deg F/min
		Cold	32	150	
Coolant, crossover out	Deg F	Hot	32	300	Up: 12 Deg F/min Down: 28 Deg F/min
		Cold		150	
Coolant, cover-breather flow	GPM	0	10		
Coolant, Xover flow	GPM	0	10		
Coolant, jacket out	Deg F	32	300	Up: 12 Deg F/min Down: 28 Deg F/min	
Coolant, jacket in	Deg F	32	300	Up: 12 Deg F/min Down: 28 Deg F/min	
Coolant, Xover out	Deg F	32	300	Up: 12 Deg F/min Down: 28 Deg F/min	

Appendix D1 (cont...)

"Suggested Static and Dynamic Limits for Rejecting Bad Quality Data"

SEQUENCE IID TEST (continued)

PARAMETER		STATIC LIMITS		RATE OF CHANGE LIMIT
		MINIMUM	MAXIMUM	
Air Fuel ratio		0	20	
Fuel inlet temp	Deg F	0	150	
Carb air temp	Deg F	32	100	10 Deg F/min
Humidity	Gr/lb	0	100	
Carb Air pressure	InH <sub>2</sub> O	-200	1	
Ambient Air Temp	Deg F	0	150	
blowby gas outlet temp	Deg F	32	350	
blowby	CFM	0	3	
Right exhaust pressure	InH <sub>2</sub> O	0	50	
Left exhaust pressure	InH <sub>2</sub> O	0	50	
Diff. exhaust pressure	InH <sub>2</sub> O	0	2	
Intake Vacuum	InHG	0	35	
Intake mixture temp	Deg F	32	150	
Crankcase pressure	InH <sub>2</sub> O	0	5	Up: 1.6 In H <sub>2</sub> O/sec Down: 5 In Hg/sec

Appendix D1 (cont...)

"Suggested Static and Dynamic Limits for Rejecting Bad Quality Data"

SEQUENCE TEST

PARAMETER		STATIC LIMITS		RATE OF CHANGE LIMIT
		MINIMUM	MAXIMUM	
Average speed	RPM	0	4000	Up: 88 RPM/sec Down: 165 RPM/sec
Brake Load	Lb-ft	0	200	
B.H.P.		0	150	
Oil at filter block	Deg F	32	400	Up: 20 Deg F/min Down: 60 Deg F/min
Oil pan temperature	Deg F	32	400	Up: 20 Deg F/min Down: 60 Deg F/min
Oil pump outlet press	psi	0	100	30 psi/sec
Oil, engine pressure	psi	0	100	30 psi/sec
Coolant, jacket out	Deg F	32	300	Up: 12 Deg F/min Down: 28 Deg F/min
Coolant, jacket in	Deg F	32	300	Up: 12 Deg F/min Down: 28 Deg F/min
Coolant, jacket flow	GPM	0	100	
Coolant, Breather out	Deg F	32	300	Up: 12 Deg F/min Down: 28 Deg F/min
Coolant, left cover out	Deg F	32	300	Up: 12 Deg F/min Down: 28 Deg F/min
Coolant, rt cover out	Deg F	32	300	Up: 12 Deg F/min Down: 28 Deg F/min
Coolant, cover flow	GPM	0	10	
Coolant, breather tube flow	GPM	0	10	
Air Fuel ratio		0	20	
Fuel inlet temp	Deg F	0	150	
Carb air temp	Deg F	32	100	10 Deg F/min
Humidity	Gr/lb	0	100	
Carb Air pressure	InH2O	-200	1	
Ambient Air Temp	Deg F	0	150	
Blowby gas outlet temp	Deg F	32	350	
Blowby	GPM	0	3	
Right exhaust pressure	InH2O	0	50	
Left exhaust pressure	InH2O	0	50	
Diff. exhaust pressure	InH2O	0	2	
Intake Vacuum	InHG	0	35	
Intake mixture temp	Deg F	32	150	
Crankcase pressure	InH2O	0	5	Up: 1.6 InH2O/sec Down: 5 InHg/sec
Spark timing	BTDC	0	60	

Appendix D1 (cont...)

\*Suggested Static and Dynamic Limits for Rejecting Bad Quality Data\*

SEQUENCE V-0 OPERATING REGIME

	Phase <u>I (Rate/Chg.)</u>	Phase <u>II (Rate/Chg.)</u>	Phase <u>III (Rate/Chg.)</u>
Speed, RPM	Max. 7000 Min. 0	7000 0	7000 0
Torque, ft-lbs	Max. 130 Min. 0	130 0	130 0
Oil In, °F	Max. 350 (5.0 °F/min.) Min. 50 (1.0 °F/min.)	350 (3.5 °F/min.) 50 (2.0 °F/min.)	350 (1.7 °F/min.) 50 (1.7 °F/min.)
Coolant Out, °F	Max. 240 (15.0 °F/min) Min. 32 (2.2 °F/min)	240 (14.4 °F/min) 32 (10.0 °F/min)	240 (3.6 °F/min) 32 (2.0 °F/min)
Carb. Air, °F	Max. 250 (3.2 °F/min) Min. 32 (3.3 °F/min)	250 (3.2 °F/min) 32 (3.3 °F/min)	250 (3.2 °F/min) 32 (5.0 °F/min)
Carb. Air Press., In. H <sub>2</sub> O	Max. 20 Min. -200.0	20 -200.0	20 -200.0
Cooldown Time, Minutes	Max. --- Min. ---	--- ---	--- 5 (9.0 °F/min)
DewPoint, °F	Max. 110 Min. 32	110 32	110 32
Exhaust Back Press., In. H <sub>2</sub> O	Max. 400 Min. 0	400 0	400 0
Slowby Coolant, °F	Max. 240 (15.0 °F/min) Min. 32 (2.2 °F/min)	240 (14.4 °F/min) 32 (10.0 °F/min)	240 (3.6 °F/min) 32 (20.0 °F/min)
Slowby Gas, °F	Max. 350 Min. 32	350 32	350 32
Marine Manifold, °F	Max. 240 Min. 32	240 32	240 32
Int. Vacuum, In. Hg.	Max. 33 Min. 0	33 0	33 0
Timing	Max. 76°BTDC Min. 7°ATC	76°BTDC 7°ATC	50°BTDC 7°ATC
Barom. Press., In. Hg.	Max. --- Min. ---	33 20	--- ---
Crank. Press., In. H <sub>2</sub> O	Max. 20 Min. -10	20 -10	20 -10
Fuel Flow, lb/hr	Max. 25.0 Min. 0	25.0 0	10.0 0

Appendix D1 (Cont...)

"Suggested Static and Dynamic Limits for Rejecting Bad Quality Data"

L-38 TEST

PARAMETER		STATIC LIMITS		RATE OF CHANGE	
		MINIMUM	MAXIMUM	LIMIT	
Average speed	RPM	0	6000	Up: 88 RPM/sec Down: 165 RPM/sec	
Brake Load	Lb-ft	0	32.6		
B.H.P.		0	13.5		
Intake air to engine	Deg F	32	160		10 Deg F/min
Dynamometer water	Deg F	32	212		
Water In	Deg F	32	212	Up: 12 Deg F/min Down: 28 Deg F/min	
Water Out	Deg F	32	212	Up: 12 Deg F/min Down: 28 Deg F/min	
Oil Gallery	Deg F	32	400	Up: 10 Deg F/min Down: 22 Deg F/min	
Oil Sump	Deg F	32	400	Up: 10 Deg F/min Down: 14 Deg F/min	
Heater	Watts	0	3000		
Intake Pressure or vac.	InHg	-0.5	-15		
Crankcase vacuum	InH <sub>2</sub> O	-15	15	Up: 1.6 InH <sub>2</sub> O/se Down: 5 InHg/sec	
Exhaust Back press.	InHg	-2	10		1.2 InHg/sec
Oil Gallery Press.	psi	0	100		30 psi/sec
Fuel time	sec/lb	0	400		
Intake air	lb/hr	0	185		
Rocker Air flow	CFH	0	40		
Off gas flow	CFH	0	40		

Appendix D1 (cont...)

"Suggested Static and Dynamic Limits for Rejecting Bad Quality Data"

CATERPILLAR 1H AND 1G TESTS



PARAMETER		STATIC LIMITS		RATE OF CHANGE
		MINIMUM	MAXIMUM	LIMIT
Average Speed	R.P.M.	0	2600	100 RPM/sec
B.H.P.		0	55	
Humidity	Grains/LB	0	300	10 Gr/LB/min
Intake Air to Engine	Deg F	40	350	4 Deg F/min
Water In	Deg F	40	220	14 Deg F/min
Water Out	Deg F	40	220	14 Deg F/min
Coolant Delta	Deg F	0	20	
Oil Gallery	Deg F	40	220	18 Deg F/min
Oil Cooler Inlet	Deg F	40	220	18 Deg F/min
Exhaust Temperature	Deg F	60	1300	
Boost pressure	In Hg	27	60	1 In Hg/sec
Crankcase vacuum	In H2O	-5	5	
Exhaust back pressure	In Hg	0	20	
Fuel pressure	psi	0	100	
Oil Gallery pressure	psi	0	100	16 psi/min
Cooling jet pressure	psi	0	100	16 psi/min
B.T.U. / Minute		0	6500	
Blowby	C.F.H.	0	80	

MANOMETER STEP RESPONSE DATA SYNOPSIS

<u>Fluid</u>	<u>Orifice</u>	<u>Time (Seconds) To % F.S. (30")</u>			<u>Frequency Response (Hz)</u>	
		<u>10%</u>	<u>63%</u>	<u>90%</u>	<u>.4/(90%-10%)</u>	<u>.159/63%</u>
Hg	5/8"	.10	.35	.58	.83	.45
	3/64"	.20	.46	.70	.80	.35
#4 Green S.G.=1.000	5/8"	.10	.43	.72	.64	.37
	3/64"	.15	.45	.79	.63	.35
100% Glycol 1 Tube	5/8"	.12	.76	1.93	.22	.21
	3/64"	.20	.94	2.96	.14	.17
100% Glycol 2 Tubes	5/8"	.15	.93	2.55	.17	.17
	3/64"	.20	1.36	3.60	.12	.12

9/23/86

Appendix D2 (Cont...)



FREQUENCY RESPONSE FOR  
MERIAM 30" MANOMETER

23 Sept. 1986

Appendix D3


RTD AND T/C RESPONSE TIMES

<u>Probe Type</u>	<u>Length In.</u>	<u>Depth In.</u>	<u>Oil Temp °F</u>	<u>99% Sec</u>	<u>63% Sec</u>	<u><math>f = \frac{2\pi}{63\%}</math> Hz</u>
3/16 RTD Closed	6	1.87	200 300	50.16 44.89	15.83 14.28	.010 .011
3/16J T/C Closed	6	1.87	200 300	37.35 28.39	11.07 9.45	.014 .017
3/16J T/C Closed	3	1.87	200 300	42.67 32.11	12.01 9.81	.013 .016
1/8J T/C Closed	6	1.25	200 300	22.70 17.63	6.47 5.67	.025 .028
1/4J T/C Flex Closed	6	2.50	200 300	70.70 54.00	21.04 16.77	.008 .009
1/4J T/C Closed	4	2.50	200 300	78.18 60.28	21.53 17.27	.007 .009
1/4J T/C Open	3	2.50	200 300	30.24 17.81	3.82 2.59	.042 .061

Times are averaged for 4-5 repeats per point.

Robert Ratliff  
EG&G-AR  
10/27/86


EQUIPMENT SKETCH



- Notes:
1. Immersion depth quite critical for repeatable readings. Fixtures in both mediums were required.
  2. Ice bath measured with standards prior to readings. Range was 31.5°F to 32.0°F.
  3. Oil bath was set to 200.0°F and 300.0°F.

EG&G-AR  
 Robert Ratliff  
 10-27-86

10sec logs 18.34 psig mean  
SD = 2.46 psig



frequency 15 Hz


Engine speed 1800 RPM

No damping

CAT #4

FUEL PRESSURE CPO1

7-17-86



175 PSI  
14.5 PSI

frequency 15 Hz

Engine speed 1800 RPM

Mechanical damping, valve to  
~~Xducer~~ cracked open

CAT 4

FUEL PRESSURE CPO1

7-11-86

10sec logs 2.04 PSIG  
SD = 0.08 PSIG

Electronic filter added

2 19.9 PSIG

Engine speed 1800 RPM

CAT # 4

FUEL PRESSURE CPO1

7-17-86

Appendix D5 (Cont...)

E-1-86

filename: tcel\TC14resp.S86

R.Belling (FL)  
D.Smolenski (FL)

J.Howes  
R.Tidrow

Users Request:

We have been asked to indicate the frequency response of the control systems in TC-14. We understand the interest is to determine the system response using the automatic technique versus previously used manual processes.

A series of curves were provided to help develop a statement of the system response for each of several parameters. The curves are the output signal to some step input change. Two curves for each output were provided, one an expanded section of the first.

General Statements of the system:

In general the response of a system is based on the change in the output for some change on the input. Ideally the input command is a step change. There might be some latency or delay time before the output reacts to the input change, this should be considered in the statement of response. We did review the files on the TC-14 disk and find the particular recordings. The command step is not documented. We had neglected to ask Belling for this info.

Our statement of response is based only on the curves provided.

Several of the output curves have characteristics which display some of the forcing functions we would expect from the control algorithms, such as a large fast change and then a tapering off as it nears the final value, rather than a purely underdamped or overdamped response curve. While this varies from the text book variety the general features suggest our use of the standard formula should be acceptable.


We understand R.Belling tried not to incorporate any additional pre-analog filtering nor any special digital filtering to better simulate what the other users might have with their manual systems. The CATS system does have 1.5 Hz anti aliasing passive filters on the Computer Products Inc analog input channels. The PID control loop constants assigned (gain, integral and differential factors) in the CATS software act as system filters. We don't have numbers that we can pre-assign to these effects, so presently rely on test output characteristics. The control can be speeded up or slowed down by changing these factors. R.Belling has them operating at the speed he feels is right.

Users Test Data:


The analog plots supplied by the user show a control step of some finite value.

Appendix D5 (Cont...)

This step change may only be a small portion of the full range. In developing a statement of the time it takes for the output circuit to reach the final level we are considering the final value shown on the plots to be the full scale range. This could be interpreted as a small signal change and may not accurately describe the time to reach the final level over a large command change.



The frequency vs amplitude ratio plot (Bode plot) is frequently used when describing signal circuits and is used by the designer when developing the separate blocks of the control system. The Bode plot shows at what frequency the circuit will begin to attenuate signals. We've include the breakpoint frequency (point where the signal is attenuated 3 db) of such a plot in specifying each circuit.



Based on the above discussion we've made a statement of the response time, that describes the output curve in a general sense. We have guessitimated the command start location in 'time' to have the calculated response better match the real input signal.

The response is stated in terms of the time to reach approximately 99% of the final value (usually considered 5 time constants, but in our curve interpretation the value is reached much sooner). The time period is listed in seconds and in time constants (which is based on the time for the first time constant). The frequency break point value used in the Bode plot is also shown.

Based on standard formulas one time constant is 63.8% of final value and 5 time constants is 99% of final value. We will consider the final value as the average final level as shown in the plots.

In the case of TC-14;

## Appendix D5 (Cont...)

### 1. Flow:

#### a. Breather Tube Coolant Flow:

Time for final value (~ 99%), 1.34 seconds.  
, 1.62 Time Constants.

The break point frequency from the formula

$$F(\text{break}) = 1/(2*\text{PI}*\text{time constant})$$

, 0.194 or ~ 0.2 Hz

These values would be different if a delay time were added.  
The final value time would be longer and the frequency  
would be slower.

#### b. Right Rocker Cover Coolant Flow:

Time for final value (~99%), 0.30 seconds.  
, eq1 or 20 TC's.

$$F(\text{break}) = 1.0 \text{ Hz}$$

The higher freq appears in error but its calculated on  
one time constant where the output slews rapidly  
then the output slows down as it nears the final value.

#### c. Rocker Flow:

Time for final value (99%), 1.7 seconds.  
, 5.17 TC's

$$F(\text{break}) = 0.9 \text{ Hz}$$

#### d. Water Flow Through the Cooling Jacket:

Time for final value (99%), 7.9 seconds.  
, 1.6 TC's.

$$F(\text{break}) = 0.03 \text{ Hz}$$

### 2. Pressure:

#### a. Carburetor Air Pressure:

Time for final value (99%), 10 seconds.  
, 4 TC's.  
(Really need trailing edge of control curve)

$$F(\text{break}) = 0.06 \text{ Hz}$$

#### b. Engine Oil Pressure:

Time for final value (99%), 8.3 seconds.  
, 2.25 TC's.

$$F(\text{break}) = 0.04 \text{ Hz}$$

Appendix D5 (Cont...)

c. Left Exhaust Pressure;

Time for final value (99%), 16 seconds,  
, 2 TC's.

$$F(\text{break}) = 0.01 \text{ Hz}$$

3. Engine Torque;

Time for final value (99%), 5.8 seconds,  
, 2.4 TC's.

$$F(\text{break}) = 0.06 \text{ Hz.}$$

4. Dyno Speed:

Time for final value (99%), 5.8 seconds.  
, 2 TC's.

$$F(\text{break}) = 0.05 \text{ Hz.}$$

The user may determine the above analysis is sufficient. We'll leave it to your discretion. We plan to use the TC-14 site as an example of our systems and will document the operation in more detail.

R.Spain

References:

Plot reproduced from;

"Active Filter Products: Design and Selection" manual, by  
Frequency Devices Inc,  
25 Locust Str,  
Haverhill, Mass, 01830

Articles:

"Frequency Response of The Process",  
Instruments and Control Systems", Vol 36, Pg 136, Sept 1963.  
"Frequency Response Analysis", ISA Journal, Feb 1962, Vol 9,  
No. 2, Pg 25.

BTCFL30


BREATHER TUBE COOLANT FLOW

APPENDIX 00-10000...



Breather Tube  
Coolant  
Flow

BTCFL30 EU  
030 (PI)



Rec = 1  
FREQ3  
15:21:12 07/17/86


Minimum	Min @	Maximum	Max @	Average	Std Dev
4.025	189	9.185	126	7.334	1.816

X axis is time in seconds

(4)

BTC FL 30

BTCFL30 EU  
030 (PI)



Rec = 1  
FREQ3  
15:21:12 07/17/86

Minimum	Min @	Maximum	Max @	Average	Std Dev
4.285	158	8.835	140	6.377	1.898

X axis is time in seconds

$$TC = \frac{1}{2\pi f_b RC}$$

$$f_b = 3 \text{ db } \Delta T$$

$$f_b \approx 0.2 \text{ Hz}$$

(6)


R R C F L S S

RIGHT ROCKER COVER COOLANT FLOW

12

10.3

RT Rocker  
COVER  
COOLANT  
FLOW




Rec = 1  
FREQ4  
15:31:54 07/17/86  
X axis is time in seconds

Minimum	Min #	Maximum	Max #	Average	Std Dev
2.822	199	5.786	110	5.07	.9114
3.396	161	4.929	144	3.991	.5818

6

R R C F L S S



Rec = 1  
FREQ4  
15:31:54 07/17/86  
X axis is time in seconds


Minimum	Min #	Maximum	Max #	Average	Std Dev
2.822	199	5.554	162	3.427	.9053

5


RCTOTF27

ROCKER COVER flow

3




RCTOTF27




4

CARBPR  
CARBUZTOR AIR PRESSURE



*12/5*

*1/2/86*



①


# ENGINE OIL PRESSURE

5

OPENG

Engine reset


*Substantiated  
3000 to 2000 rpm*



Rec = 1  
FREQ = 7  
13:18:50 07/18/86

Minimum	Min @	Maximum	Max @	Average	Std Dev
113.2	200	194.6	1	173.8	29.11

*Time of  
LOG discrepancy*



Rec = 1  
FRE = 7  
13:18:50 07/18/86


Minimum	Min @	Maximum	Max @	Average	Std Dev
113.2	200	193	113	149.2	28.99

*10. K... sec*

LEXPR


LEFT Exhaust Pressure

16



Rec = 1  
 FREQ2  
 15:00:31 07/17/86  
 X axis is time in seconds

Minimum	Min @	Maximum	Max @	Average	Std Dev
3.354	171	4.996	98	4.529	.6234



Rec = 1  
 FREQ2  
 15:00:31 07/17/86  
 X axis is time in seconds



Minimum	Min @	Maximum	Max @	Average	Std Dev
3.396	161	4.929	144	3.991	.5818

3

17

ETORQ 4

*Handwritten notes:*  
 8  
 9





9

88

DYNORPM

*Handwritten:* Freq




*Handwritten:* 88


ECO OLF

WATER FLOW THROUGH THE COOLING JACKET

9




Page 2



2

DIFXPR DIFFERENTIAL Exh PRESS

10



RAC = 1  
 FREQ2  
 15:00:31 07/17/86  
 X axis is time in seconds

Minimum	Min #	Maximum	Max #	Average	Std Dev
-.1345	33	.1354	120	-.01421	.05592

4

NOT EVALUATED

# WET/WET DIFFERENTIAL PRESSURE TRANSDUCERS

This catalog describes Sensotec's complete range of strain gage wet/wet (will accept fluid into both pressure welded, stainless steel diaphragm) differential pressure transducers. There are three BASIC ACCURACIES, 1% (0.5%), available for wet/wet models. The accuracy is the combined effect of linearity, hysteresis, and repeatability. Subminiature wet/wet differential unit.

## LOW RANGE WET/WET 0.5 to 30 psid

Range	Output	Accuracy AS PER DATA	Line Pressure (5000 psi)	Maximum Overload One Side
0-5 psid	1.0 mv/psi	A-5		1500 psi
1-10	1.5	A-5		
2-20	1.5	A-5		
5-50	2.0	A-5 or 2		
10-100	2.0	A-5 or 2		
15-150	2.0	A-5 or 2		
30-300	2.0	A-5 or 2		

**SPECIFICATIONS**  
 Input: 4-10 Vdc  
 Bridge: 350 ohms  
 Operating Temperature Range: 30°F to 130°F  
 Special Option: 10°F to 195°F  
 Compensated Range: 30°F to 130°F  
 Vented Material: Inert-welded  
 Pressure Chamber Volume: approx. 0.1 in.  
 Weight: 2.5 pounds  
 Drain Ports: Standard  
 Sealing: Seal in Pressure Port Zone (metal seals optional)  
 Volume Change for all seals (normal for 2 brass, 0.1 in.)  
 Temperature Compensation for Zero & Span: 1% for  
 steel case, 0.5% for aluminum  
 Volume Capacity: 2.5 cubic inches (aluminum case only)

Labels in diagram:  
 - ELEC. CONNECTOR - BENDER P/N: 10-6P-1  
 - MOUNTING HOLES - 1/4" DIA. UNF. X 0.125" DEEP  
 - PRESSURE PORTS - 1/4" DIA. UNF. X 0.125" DEEP  
 - O-RINGS - 1/8" DIA. X 0.125" THICK

Notes:  
 All low range (0.5 to 30 psid) units are also available with output of 100 mv/psi. These units have a range and output linearity of 0.5% or better. The oil is completely sealed and cannot leak out. Available in stainless steel or aluminum.  
 The wet/wet design is available with compensated accuracy range of 0.001 psi or 0.001 psi/psi. Accuracy is 0.5% or better.  
 Accuracy reduced for:  
 - Output: 0.001 psi/psi  
 - Output: 0.001 psi/psi

### SUBMINIATURE P30P WET/WET

Range	Linearity & Hysteresis (BFSL)	Line Pressure	Output	Input
5, 10, 15, 30 psid	0.5%	250 psi	100 mv	10v

# AL PRESSURE

0.5 psid to 10

th pressure ports because each port has a  
 ACIES. TJE (0.1%), Z (0.25%), and A 5  
 d repeatability. Also presented is the P30P

3 STANDAF  
 3 BASIC AC  
 0.1%, 0.25%

## MID RANGE WET/ WET 50 psid to 750 psid



Range	Accuracy	Line Pressure	Overhead Dia. Size
50 psid	TJE = 0.1% Z = 0.25% A = 5%	1500 psi	1.500 in.
100			
150			
200			
300			
500			
750			

**SPECIFICATIONS**

- Input: 10Vdc
- Output: 2 mV/psi
- Bridges: 350 ohms
- Weight: 4.5 grams
- Compensated Range: 50 to 750
- Wetted Material: 17-4 ph stainless
- O-Ring Seals: Buna N (optional)
- Pressure-Port Volume: 0.25 cc
- Operating Temperature Range: -40 to 250
- Natural Frequency: 7500 Hz @ 200 psid
- Volume Change: 0.01% @ 200 psid range
- Temperature Compensation: Specified to 200 & 500
- TJE = 0.1% over compensated range
- Z = 0.25%
- A = 5%

**SPECIAL FEATURES** ... 507 A-5 Series Amplifier

Range	Weight: lbs. oz.	Line Pressure	Overhead Dia.	Weight
50 psid	2.00	1500 psi	1.500 in.	1.500 lbs.
100 psid	2.00	1500 psi	1.500 in.	1.500 lbs.
150 psid	2.00	1500 psi	1.500 in.	1.500 lbs.
200 psid	2.00	1500 psi	1.500 in.	1.500 lbs.
300 psid	2.00	1500 psi	1.500 in.	1.500 lbs.
500 psid	2.00	1500 psi	1.500 in.	1.500 lbs.
750 psid	2.00	1500 psi	1.500 in.	1.500 lbs.

**OPTIONS**  
 Internal Transducer Electronics Amplifier  
 0 - 5 Volt or 4 to 20MA

TJE, Z, A 5 and A 10 Series Pressure Transducers are available for all pressure ranges with integral built in electronic amplifiers



9-24-86

filename: tcel\TC8resp.986

R. Belling (FL)  
D. Smolenski (FL)

J. Howes  
R. Tidrow

**Users Request;**

R. Belling asked that we make a comparative analysis of the test system response performed in TC-8 as was done for the test data from TC-14. R. Belling will supply the test data to the ASTM sub committee.

**General Statements of the Test Set Up;**

In this case a group of time response statements were provided as were documented from TC-8 when running a similar test to that in TC-14. In this installation all controls are manually positioned for the next desired setting. The change in process may be done by simple valve change or be accomplished by manually re-positioning the command dial on a pneumatic controller (Moore).

The ranges are as previously documented, that is only a comparative incremental change has been made and the time recorded (manually).

**Manually Response Data;**

The information is stated in direct comparison to the automatically controlled information previously supplied.

**1. Flow:**

**a. Breather Tube System (coolant flow);**

Flow change from 3 gal to 2 gal/min (by manual valve change);

Time to approach the or strike the maximum value was 6 seconds.

Time to stabilize to the final value, 15 seconds.

The break point frequency from the formula

$$F(\text{break}) = 1/(2\pi \text{time constant})$$

$$\text{One time constant (TC)} = 63.8\% \times 6 = 3.8 \text{ sec}$$

$$F(\text{break}) = 0.04 \text{ Hz}$$

(This compares to 0.2 Hz for the auto process)

**b. Rocker Cover Coolant Flow;**

Flow change from 3 gal to 2 gal/min (by manual valve change);

APPENDIX D6 (Cont...)

Time to approach the or strike the maximum value was 7 seconds.  
Time to stabilize to the final value, 14 seconds.

The break point frequency from the formula

$$\text{One time constant (TC)} = 63.8\% \times 7 = 4.47 \text{ sec}$$

$$F(\text{break}) = 0.035 \text{ Hz}$$

(This compares to 1.0 Hz for the auto process)

c. Engine Coolant Flow;

Flow change from 40 gal to 38 gal/min (by manually resetting a Moore pneumatic controller);

Time to approach the or strike the maximum value was 20 seconds.

Time to stabilize to the final value, 97 seconds.

The break point frequency from the formula

$$\text{One time constant (TC)} = 63.8\% \times 20 = 12.8 \text{ sec}$$

$$F(\text{break}) = 0.012 \text{ Hz}$$

(This compares to 0.3 Hz for the auto process)

D. Pressure:

a. Carburetor Pressure;

Pressure change from 0.02" H<sub>2</sub>O to 0.01" H<sub>2</sub>O (by manually resetting a Moore pneumatic controller);

Time to approach the or strike the maximum value was 18 seconds.

Time to stabilize to the final value, 33 seconds.

The break point frequency from the formula

$$\text{One time constant (TC)} = 63.8\% \times 18 = 11.5 \text{ sec}$$

$$F(\text{break}) = 0.014 \text{ Hz}$$

(This compares to 0.06 Hz for the auto process)

b. Engine Oil Pressure;

Pressure change from 40 psi to 33.5 psi (read as a gage pressure and changed by a speed change from 3000 rpm to 2000 rpm);

Time to stabilize to the final value, 8 seconds.

The break point frequency from the formula

$$\text{One time constant (TC)} = 63.8\% \times 8 = 5.1 \text{ sec}$$

$$F(\text{break}) = 0.03 \text{ Hz}$$

(This compares to 0.04 Hz for the auto process)

c. Left Exhaust Pressure;

Pressure change from 4.9 kPa to 3.5 kPa (by manually resetting a Moore pneumatic controller);

Time to approach the or strike the maximum value was 5 seconds.

Time to stabilize to the final value, 35 seconds.

The break point frequency from the formula

$$\text{One time constant (TC)} = 63.8\% \times 5 = 3.2 \text{ sec}$$

$$F(\text{break}) = 0.05 \text{ Hz}$$

(This compares to 0.01 Hz for the auto process)

d. Engine Torque:

Torque change from 160 Nm to 130 Nm (by adjusting an electrical servo for Throttle Position);

Time to approach the or strike the maximum value was 13 seconds.

Time to stabilize to the final value, 35 seconds.

The break point frequency from the formula

$$\text{One time constant (TC)} = 63.8\% \times 13 = 8.3 \text{ sec}$$

$$F(\text{break}) = 0.02 \text{ Hz}$$

(This compares to 0.06 Hz for the auto process)

e. Dyno Speed;

Speed change from 3000 rpm to 2000 rpm (by adjusting the speed pot on the dyno control panel);

Time to approach the or strike the maximum value was 8 seconds.

Time to stabilize to the final value, 15 seconds.

The break point frequency from the formula

$$\text{One time constant (TC)} = 63.8\% \times B = 5.1 \text{ sec}$$

$$F(\text{break}) = 0.03 \text{ Hz}$$

(This compares to 0.05 Hz for the auto process)

R. Spain  
Instrumentation Dept

Attachment; Comparison Chart

filename: tc14vstc8 (ALT U) Lotus

Comparison Chart for Response Data between the Test Cell 14  
(computerized) and Test Cell 8 (Manual) control systems

Control Parameter	Reach Max Value(Sec) TC-14/8	Final Value(Sec) TC-14/8	One Time Const TC-14/8	F(break) Hz TC-14/8
Breather Flow Cool	1.34/6	---/15	0.82/3.2	0.2/0.04
Rocker Cov Cool Flow	0.3/7	30/14	0.15/4.47	1.0/0.035
Engine Cool Flow	6/20	---/97	4.9/12.8	0.03/0.012
Carburetor Press	5/19	10/33	2.5/11.5	0.06/0.014
Engine Oil Press	7.4/8	---	3.7/5.1	0.04/0.03
Left Exh Press	16/5	20/35	8/3.2	0.01/0.05
Engine Torque	2/13	5.8/35	2.4/8.3	0.06/0.02
Dyno Speed	5.4/8	5.4/15	2.9/5.1	0.05/0.03


(12.11)  
EXHIBIT MEASURE 4 (SD)



12.11.11

*Cat Beest Pressure*


DATE 25 26 TIME 24 51 25 CH. NO 1 2 3 4 5 6 7 8 9 10 11 12 0.01 SECS N. T. I. DENVER. NUM NO



APPENDIX D7 (Cont...)

*Beest Pressure*

*SECRET 1156*




5001; 1187

APPENDIX D7 (Cont...)

*Coil Condenser Pressure*

*1000 3 NI*

ITEM: NUN NO 07 COTS 02 30 36 TIME 24 00 00 GR-NUM 2 2 3 4 5 6 7 0 P 20 22 24 002 SAYS



SECRET, 1986

## RELATIONSHIP BETWEEN

- a) DIGITAL 1<sup>ST</sup> ORDER FILTER
- b) ROLLING AVERAGE FILTER
- c) BLOCK AVERAGE FILTER

AND THE CLASSICAL ANALOG 1<sup>ST</sup> ORDER FILTER

## DEFINITION OF SYMBOLS

$f$ : FREQUENCY OF INPUT FUNCTION

$T$ : PERIOD OF INPUT FUNCTION ( $= 1/f$ ) 200 sec for example:

$f_s$ : SAMPLING FREQUENCY

$T_s$ : SAMPLE TIME PERIOD ( $= 1/f_s$ ) 1 sec for examples

$f_c$ : CLASSICAL ANALOG FILTER CUTOFF FREQUENCY  $\times f$  for example

$\tau_c$ : CLASSICAL TIME CONSTANT ( $= \frac{1}{2\pi f_c}$ )

$T_{RA}$ : ROLLING AVERAGE TIME PERIOD  $\cong 2\tau_c$  for best fit, see examp.

$T_{BA}$ : BLOCK AVERAGE TIME PERIOD  $\cong \tau_c$  for best fit, see examples

## FORMULAS

DIGITAL 1<sup>ST</sup> ORDER FILTER


$$\text{OUT}(i) = [e^{-T_s/\tau_c}] \text{OUT}(i-1) + [1 - e^{-T_s/\tau_c}] \text{IN}(i)$$

## ROLLING AVERAGE FILTER


$$\text{OUT}(i) = \frac{T_s}{T_{RA}} \sum_{(i-T_{RA}/T_s+1)}^i \text{IN}(j)$$

## BLOCK AVERAGE FILTER


$$\text{OUT}(i) \text{ thru } \text{OUT}(i+T_{BA}/T_s-1) = \frac{T_s}{T_{BA}} \sum_{(i-T_{BA}/T_s+1)}^i \text{IN}(j)$$



$$f_c = 5f$$
$$\gamma_c = \frac{1}{2\pi f_c}$$
$$T_{RA} = \frac{1}{\pi f_c}$$
$$T_{BA} = \frac{1}{2\pi f_c}$$



$$f_c = 2f$$
$$T_c = \frac{1}{2\pi f_c}$$
$$T_{RA} = \frac{1}{\pi f_c}$$
$$T_{BA} = \frac{1}{2\pi f_c}$$




$$f_c = f$$

$$r_c = \frac{1}{2\pi f_c}$$

$$T_{RA} = \frac{1}{\pi f_c}$$

$$T_{BA} = \frac{1}{2\pi f_c}$$




$$f_c = .5f$$

$$T_c = \frac{1}{2\pi f_c}$$

$$T_{RA} = \frac{1}{\pi f_c}$$

$$T_{BA} = \frac{1}{2\pi f_c}$$




$$f_c = 2f$$

$$r_c = \frac{1}{2\pi f_c}$$

$$T_{RA} = \frac{1}{\pi f_c}$$

$$T_{BA} = \frac{1}{2\pi f_c}$$




$$f_c = 2f$$

$$\tau_c = \frac{1}{2\pi f_c}$$

$$T_{RA} = \frac{1}{\pi f_c}$$

$$T_{BA} = \frac{1}{2\pi f_c}$$



$$f_c = 2f$$

$$\tau_c = \frac{1}{2\pi f_c}$$

$$T_{RA} = \frac{1}{\pi f_c}$$

$$T_{BA} = \frac{1}{2\pi f_c}$$

## APPENDIX E

### REFERENCES

1. ASTM Standard E 177 "Use of the Terms Precision and Accuracy"
2. Omega Temperature Measurement Handbook, "Comparison of Time Constants", p. T39, 1986.
3. Hy Cal Engineering Co.

*ASTM International takes no position respecting the validity of any patent rights asserted in connection with any item mentioned in this research report. Users of this research report are expressly advised that determination of the validity of any such patent rights, and the risk of infringement of such rights, are entirely their own responsibility.*

*This research report is copyrighted by ASTM International, 100 Barr Harbor Drive, PO Box C700, West Conshohocken, PA 19428-2959, United States. Individual reprints (single or multiple copies) of this research report may be obtained by contacting ASTM at the above address or at 610-832-9585 (phone), 610-832-9555 (fax), or [serviceastm.org](mailto:serviceastm.org) (e-mail); or through the ASTM website ([www.astm.org](http://www.astm.org)).*